



number	2696701/01	Replaces	-
Date of issue	25-05-2022	Issued first	25-05-2022
		Report number	P000126967

Declaration regarding the efficiency of a shower heat recovery unit

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Zypho, SA

This declaration does not pass a judgment on other products supplied by the manufacturer. The products mentioned below were tested according the procedure according annex U of the NTA 8800+A1:2020.

Zypho PiPe 75

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	47	74.5	0.15
3	9.2	73	69.2	0.33
4, 5, 6	12.5	100	66.2	0.56

Allard Slomp
Product Manager

Kiwa Nederland B.V.

Kiwa Nederland B.V.
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands
Tel. 088 998 33 55
Fax 088 998 36 85
info@kiwa.com
www.kiwaenergy.com

Zypho, SA
Rua Barão do Corvo, 37 , 1º F2.
Vila Nova De Gaia 4400-039
Portugal
+351 210 991 351
b2b@zypho.pt
www.zypho.pt

