


CERTIFICATE

Certified Passive House Component

Component-ID 1605sr00 valid until 31st December 2022

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: **Shower Water Heat Recovery**
Manufacturer: **ZYPHO,
Vila Nova de Gaia,
Portugal**
Product name: **ZYPHO iZi 40**

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions¹ the system reduces the useful energy demand for shower by

30% \geq 30%

steady-state efficiency

37%

effective dead time

5 s

design flow rate

8 l/min

Further properties

Pressure drop tap water at 8 l/min: 0.27 bar
Connection tap water: 1/2" AG
Connection waste water: DN 50

¹Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House
efficiency class

phE

phD

phC

phB

phA

phA+

all climate zones



**CERTIFIED
COMPONENT**

Passive House Institute